

Certificate

Registration No.: Q 60019450

Page 1

Report No.: 21207328-1

License Holder:

Mitsubishi Electric Corp.
Photovoltaic Power System Business Center
Nakatsugawa Works
1-3 Komaba-cho, Nakatsugawa-city
Japan

Product:

PV Modules

Types:

PV-TE115MF5N; PV-TE120MF5N;
PV-TE125MF5N; PV-TE130MF5N;
PV-TE135MF5N; PV-TD160MF5;
PV-TD165MF5; PV-TD170MF5;
PV-TD175MF5; PV-TD180MF5;
PV-TD185MF5; PV-TD190MF5;
PV-TD195MF5

Manufacturing Plant:

Mitsubishi Electric Corp.
Kyoto Works
1 Zusho baba
Nagaokakyo-shi, Kyoto-fu, 617-8550
Japan

Basis:

IEC 61215:2005
EN 61215:2005
"Crystalline silicon terrestrial
photovoltaic (PV) modules - Design
qualification and type approval"

Factory Inspection
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Periodic Inspection

Remarks:

The details of the factory inspection are documented in report no.: 21208367.
The mechanical load test of EN IEC 61215:2005 was performed with a load of 5400 Pa.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate has a validity of 5 years counting from date of issue.



Cologne, 26 September 2007

Dipl.-Ing. M. Adrian

TÜV Rheinland Product Safety GmbH, Am Grauen Stein, D-51105 Cologne